




Product Service

# Attestation of Conformity

No. N8A 15 09 93168 002

**Holder of Certificate:** Shanghai Richeng Electronics Co.,LtdNo.950,Xinlin Rd.,Xinsheng Industrial Area, Zhelin Town  
201416 Fengxian, Shanghai  
PEOPLE'S REPUBLIC OF CHINA**Product:** Cable gland

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 64100150310301**Date,** 2015-09-16  
( Boris Ouyang )

After preparation of the necessary technical documentation as well as the EU conformity declaration the required CE marking can be affixed on the product. That declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 2



**Attestation of Conformity**  
**No. N8A 15 09 93168 002**

**Model(s):**

MG12A-08, MG16A-07, MG16A-10, MG20A-11, MG20A-14,  
 MG25A-16, MG25A-18, MG32A-22, MG32A-25, MG40A-25,  
 MG40A-30, MG50A-32, MG50A-40, MG63A-46, MG63A-50,  
 PG7A-08, PG9A-05, PG9A-08, PG11A-07, PG11A-10,  
 PG13.5A-08, PG13.5A-12, PG16A-11, PG16A-14, PG21A-16,  
 PG21A-18, PG29A-22, PG29A-25, PG36A-25, PG36A-30,  
 PG42A-32, PG42A-40, MGB12S-06B, MGB12-07B, MGB12L-07B,  
 MGB16S-08B, MGB16SL-08B, MGB16-10B, MGB16L-10B, MGB18-10B,  
 MGB18L-10B, MGB20S-12B, MGB20-14B, MGB20L-14B, MGB25S-14B,  
 MGB25-18B, MGB25L-18B, MGB32-22B, MGB32-25B, MGB40-32B,  
 MGB50-40B, MGB63-46B, PGB7-07, PGB9-08, PGB13.5-12,  
 PGB16 -14, PGB19 -14, PGB21-18, PGB25-20, PGB29-25,  
 PGB36-32, PGB42-41, PGB48-46

**Parameters:**

Material of the cable glands:	Non-metallic
Type of cable anchorage:	Anchorage Type A
Impact category:	Category 1
Degree of protection:	IP54
Temperature range:	-40°C to 85 °C
Sealing system:	With a single orifice seal

**Tested according to:**

EN 62444:2013